

Certificate

of Electrical Appliance Testing

Date Tested:

16/08/2022

Certificate Number PCL-002017



**The electrical appliances on these premises (as per current
appliance register) have been inspected and tested for
electrical safety to the requirements of the Electricity at Work
Regulations**

PATCornwall
Portable Appliance Testing throughout Cornwall

Testing carried out by:

PAT Cornwall Limited
4 Roseline Estate
Carnkie
Helston
Cornwall
TR13 0XA

Phone: 01209 860665

Mobile: 07791 717358

Email: paul@patcornwall.co.uk

Web: www.patcornwall.co.uk

Certificate issued to:

Jonah`s Lift
22 Croft Parc
The Lizard
Helston
Cornwall
TR12 7PN

Appliance Register
For Site 22 CROFT PARC and all Locations

Jonah`s Lift
22 Croft Parc
The Lizard
Helston
Cornwall
TR12 7PN



PAT Cornwall Limited
4 Roseline Estate
Carnkie
Helston
Cornwall
TR13 0XA
Phone: 01209 860665
Mobile: 07791 717358
Email: paul@patcornwall.co.uk
Web: www.patcornwall.co.uk

Appliance Description	Appliance Id	Test Date	ReTest Date	Status
EXTENSION CABLE 4 WAY	E03391681	16/08/22	16/08/23	PASS
AC ADAPTOR	P0023584	16/08/22	16/08/23	PASS
AC ADAPTOR	P0012175	16/08/22	16/08/23	PASS
POWER LEAD	C0021455	16/08/22	16/08/23	PASS
POWER SUPPLY	P0060021	16/08/22	16/08/23	PASS
POWER LEAD	C0006476	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	E03391686	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	C0025029	16/08/22	16/08/23	PASS
POWER LEAD	P0012171	16/08/22	16/08/23	PASS
POWER LEAD	C0006479	16/08/22	16/08/23	PASS
POWER LEAD	P0060020	16/08/22	16/08/23	PASS
POWER LEAD	C0006475	16/08/22	16/08/23	PASS
POWER LEAD	C0006474	16/08/22	16/08/23	PASS
POWER LEAD	C0006808	16/08/22	16/08/23	PASS
POWER LEAD	C0006807	16/08/22	16/08/23	PASS
AC ADAPTOR	P0070420	16/08/22	16/08/23	PASS
POWER LEAD	C0006478	16/08/22	16/08/23	PASS
POWER LEAD	P0017746	16/08/22	16/08/23	PASS
POWER LEAD	P0017748	16/08/22	16/08/23	PASS
POWER LEAD	P0009080	16/08/22	16/08/23	PASS
POWER LEAD	C0006472	16/08/22	16/08/23	PASS
POWER LEAD	C0016069	16/08/22	16/08/23	PASS
EXTENSION CABLE 1 WAY	P0009079	16/08/22	16/08/23	PASS
POWER LEAD	P0017749	16/08/22	16/08/23	PASS
RCD	E03391684	16/08/22	16/08/23	PASS
POWER LEAD	P001F	16/08/22	16/08/23	FAIL
EXTENSION CABLE 4 WAY	P0044634	16/08/22	16/08/23	PASS
EXTENSION CABLE 2 WAY	P0070421	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0070422	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0060019	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0060018	16/08/22	16/08/23	PASS
EXTENSION CABLE 3 WAY	P0044637	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0044636	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0044625	16/08/22	16/08/23	PASS
EXTENSION CABLE 2 WAY	P0044641	16/08/22	16/08/23	PASS
EXTENSION CABLE 2 WAY	P0044644	16/08/22	16/08/23	PASS
EXTENSION CABLE 2 WAY	P0044633	16/08/22	16/08/23	PASS
EXTENSION CABLE 2 WAY	P0044642	16/08/22	16/08/23	PASS
EXTENSION CABLE 4 WAY	P0044639	16/08/22	16/08/23	PASS
POWER LEAD	C0016042	16/08/22	16/08/23	PASS
POWER LEAD	C0016036	16/08/22	16/08/23	PASS
POWER LEAD	C0016076	16/08/22	16/08/23	PASS
POWER LEAD	C0016074	16/08/22	16/08/23	PASS
POWER LEAD	P0044645	16/08/22	16/08/23	PASS
POWER LEAD	P0044646	16/08/22	16/08/23	PASS
POWER LEAD	C0016039	16/08/22	16/08/23	PASS
POWER LEAD	C0025030	16/08/22	16/08/23	PASS
POWER LEAD	C0016038	16/08/22	16/08/23	PASS
POWER LEAD	C0016040	16/08/22	16/08/23	PASS
POWER LEAD	C0025031	16/08/22	16/08/23	PASS
POWER LEAD	C0016078	16/08/22	16/08/23	PASS
POWER LEAD	C0016041	16/08/22	16/08/23	PASS
POWER LEAD	C0025032	16/08/22	16/08/23	PASS
POWER LEAD	C0016044	16/08/22	16/08/23	PASS


Appliance Description	Appliance Id	Test Date	ReTest Date	Status
POWER LEAD	C0016082	16/08/22	16/08/23	PASS
POWER LEAD	C0016073	16/08/22	16/08/23	PASS
POWER LEAD	C0016037	16/08/22	16/08/23	PASS
POWER LEAD	C0016043	16/08/22	16/08/23	PASS
POWER LEAD	C0016075	16/08/22	16/08/23	PASS
POWER LEAD	C0016080	16/08/22	16/08/23	PASS
POWER LEAD	P0017747	16/08/22	16/08/23	PASS
POWER LEAD	C0016071	16/08/22	16/08/23	PASS
POWER LEAD	C0025033	16/08/22	16/08/23	PASS
POWER LEAD	C0016068	16/08/22	16/08/23	PASS
POWER LEAD	C0016070	16/08/22	16/08/23	PASS
POWER LEAD	C0006471	16/08/22	16/08/23	PASS
POWER SUPPLY	P0023583	16/08/22	16/08/23	PASS
AC ADAPTOR	C0016045	16/08/22	16/08/23	PASS
AC ADAPTOR	P0009077	16/08/22	16/08/23	PASS
TRACE ELLIOT	P0044635	16/08/22	16/08/23	PASS
AC ADAPTOR	P0044630	16/08/22	16/08/23	PASS
AC ADAPTOR	P0044629	16/08/22	16/08/23	PASS
LAMP	P0060022	16/08/22	16/08/23	PASS
POWER LEAD	C0025035	16/08/22	16/08/23	PASS
LAMP	P0060023	16/08/22	16/08/23	PASS
POWER LEAD	P002F	16/08/22	16/08/23	FAIL
LAMP	P0070423	16/08/22	16/08/23	PASS
AMPLIFIER ORANGE	P0012174	16/08/22	16/08/23	PASS
AUDIO MIXER	P0044647	16/08/22	16/08/23	PASS
SPEAKERS THE BOX	P0044651	16/08/22	16/08/23	PASS
SPEAKERS LANEY	P0044652	16/08/22	16/08/23	PASS
AMPLIFIER ELECTRO VOICE	P0044649	16/08/22	16/08/23	PASS
AMPLIFIER SPEAKER ALTO	P0044632	16/08/22	16/08/23	PASS
AMPLIFIER ELECTRO VOICE	P0044650	16/08/22	16/08/23	PASS
AMPLIFIER SPEAKER ALTO	P0044631	16/08/22	16/08/23	PASS
POWER LEAD	C0016067	16/08/22	16/08/23	PASS
POWER LEAD	P003F	16/08/22	16/08/23	FAIL

PAT Report Fail

For Site 22 CROFT PARC and all Locations

CLIENT DETAILS	
Company Name:	Jonah`s Lift
Address:	22 Croft Parc The Lizard Helston Cornwall TR12 7PN



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	PAT Cornwall Limited		
Address:	4 Roseline Estate Carnie Helston Cornwall TR13 0XA	Telephone:	01209 860665
		Mobile:	07791 717358
		Email:	paul@patcornwall.co.uk
		Web:	www.patcornwall.co.uk
Cert Number:	PCL-002017	Signature:	
Order Number:			
File Name:	Download 16 August 2022 15-39		


APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
22 CROFT PARC - GARAGE										
P001F	POWER LEAD	16/08/22	P	P	F 0.60	S	S	S	FAIL	
EARTH CONTINUITY FAIL - REWIRE / SERVICE / REPAIR OR DISCARD										
P002F	POWER LEAD	16/08/22	P	P	F 0.62	S	S	S	FAIL	
EARTH CONTINUITY FAIL - REWIRE / SERVICE / REPAIR OR DISCARD										
P003F	POWER LEAD	16/08/22	P	S	F 0.60	S	S	S	FAIL	
EARTH CONTINUITY FAIL - REWIRE / SERVICE / REPAIR OR DISCARD										
									Total Appliances >	3
									Total Appliances For Report:	3

PAT Report Passes

For Site 22 CROFT PARC and all Locations

CLIENT DETAILS	
Company Name:	Jonah`s Lift
Address:	22 Croft Parc The Lizard Helston Cornwall TR12 7PN



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	PAT Cornwall Limited		
Address:	4 Roseline Estate Carnie Helston Cornwall TR13 0XA	Telephone:	01209 860665
		Mobile:	07791 717358
		Email:	paul@patcornwall.co.uk
		Web:	www.patcornwall.co.uk
Cert Number:	PCL-002017	Signature:	
Order Number:			
File Name:	Download 16 August 2022 15-39		

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
22 CROFT PARC - GARAGE									
E03391681	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.15	P >99.9	S	S	PASS
P0023584	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS
P0012175	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS
C0021455	POWER LEAD	16/08/22	P	S	S	S	S	S	PASS
P0060021	POWER SUPPLY	16/08/22	P	S	S	P >99.9	P <0.05	S	PASS
C0006476	POWER LEAD	16/08/22	P	P	P 0.72	P >99.9	S	S	PASS
E03391686	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.19	P >99.9	S	S	PASS
C0025029	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.20	P >99.9	S	S	PASS
P0012171	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS
C0006479	POWER LEAD	16/08/22	P	P	P 0.13	P >99.9	S	S	PASS
P0060020	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS
C0006475	POWER LEAD	16/08/22	P	P	P 0.22	P >99.9	S	S	PASS
C0006474	POWER LEAD	16/08/22	P	P	P 0.17	P >99.9	S	S	PASS
C0006808	POWER LEAD	16/08/22	P	P	P 0.16	P >99.9	S	S	PASS
C0006807	POWER LEAD	16/08/22	P	P	P 0.14	P >99.9	S	S	PASS
P0070420	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS
C0006478	POWER LEAD	16/08/22	P	P	P 0.17	P >99.9	S	S	PASS
P0017746	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS
P0017748	POWER LEAD	16/08/22	P	P	P 0.14	P >99.9	S	S	PASS
P0009080	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS
C0006472	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS
C0016069	POWER LEAD	16/08/22	P	P	P 0.09	P >99.9	S	S	PASS
P0009079	EXTENSION CABLE 1 WAY	16/08/22	P	P	P 0.27	P >99.9	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
P0017749	POWER LEAD	16/08/22	P	P	P 0.09	P >99.9	S	S	PASS	
E03391684	RCD	16/08/22	P	S	S	S	S	S	PASS	
P0044634	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.31	P >99.9	S	S	PASS	
P0070421	EXTENSION CABLE 2 WAY	16/08/22	P	P	P 0.31	P >99.9	S	S	PASS	
P0070422	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.16	P >99.9	S	S	PASS	
P0060019	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.15	P >99.9	S	S	PASS	
P0060018	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.15	P >99.9	S	S	PASS	
P0044637	EXTENSION CABLE 3 WAY	16/08/22	P	P	P 0.13	P >99.9	S	S	PASS	
P0044636	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.14	P >99.9	S	S	PASS	
P0044625	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.18	P 3.35	S	S	PASS	
P0044641	EXTENSION CABLE 2 WAY	16/08/22	P	P	P 0.22	P >99.9	S	S	PASS	
P0044644	EXTENSION CABLE 2 WAY	16/08/22	P	P	P 0.30	P >99.9	S	S	PASS	
P0044633	EXTENSION CABLE 2 WAY	16/08/22	P	P	P 0.31	P >99.9	S	S	PASS	
P0044642	EXTENSION CABLE 2 WAY	16/08/22	P	P	P 0.31	P >99.9	S	S	PASS	
P0044639	EXTENSION CABLE 4 WAY	16/08/22	P	P	P 0.18	P >99.9	S	S	PASS	
C0016042	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS	
C0016036	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016076	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS	
C0016074	POWER LEAD	16/08/22	P	P	P 0.13	P >99.9	S	S	PASS	
P0044645	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS	
P0044646	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016039	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0025030	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS	
C0016038	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS	
C0016040	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0025031	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016078	POWER LEAD	16/08/22	P	P	P 0.14	P >99.9	S	S	PASS	
C0016041	POWER LEAD	16/08/22	P	P	P 0.09	P >99.9	S	S	PASS	
C0025032	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS	
C0016044	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016082	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016073	POWER LEAD	16/08/22	P	P	P 0.11	P >99.9	S	S	PASS	
C0016037	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS	
C0016043	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016075	POWER LEAD	16/08/22	P	P	P 0.30	P >99.9	S	S	PASS	
C0016080	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS	
P0017747	POWER LEAD	16/08/22	P	P	P 0.19	P >99.9	S	S	PASS	
C0016071	POWER LEAD	16/08/22	P	S	S	S	S	S	PASS	
C0025033	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS	
C0016068	POWER LEAD	16/08/22	P	P	P 0.20	P >99.9	S	S	PASS	
C0016070	POWER LEAD	16/08/22	P	P	P 0.19	P >99.9	S	S	PASS	
C0006471	POWER LEAD	16/08/22	P	S	S	S	S	S	PASS	
P0023583	POWER SUPPLY	16/08/22	P	S	S	P >99.9	P <0.05	S	PASS	
C0016045	AC ADAPTOR	16/08/22	P	S	S	P >99.9	S	S	PASS	
P0009077	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS	
P0044635	TRACE ELLIOT	16/08/22	P	S	P 0.19	P >99.9	P <0.05	S	PASS	
P0044630	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS	

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
P0044629	AC ADAPTOR	16/08/22	P	S	S	S	S	S	PASS
P0060022	LAMP	16/08/22	P	S	P 0.13	P >99.9	P 0.08	S	PASS
C0025035	POWER LEAD	16/08/22	P	P	P 0.12	P >99.9	S	S	PASS
P0060023	LAMP	16/08/22	P	S	P 0.13	P >99.9	P <0.05	S	PASS
P0070423	LAMP	16/08/22	P	S	P 0.11	P >99.9	P <0.05	S	PASS
P0012174	AMPLIFIER ORANGE	16/08/22	P	S	P 0.12	P >99.9	P <0.05	S	PASS
P0044647	AUDIO MIXER	16/08/22	P	S	P 0.13	P >99.9	P <0.05	S	PASS
P0044651	SPEAKERS THE BOX	16/08/22	P	S	P 0.15	P >99.9	P <0.05	S	PASS
P0044652	SPEAKERS LANEY	16/08/22	P	S	P 0.24	P >99.9	P <0.05	S	PASS
P0044649	AMPLIFIER ELECTRO VOICE	16/08/22	P	S	P 0.12	P >99.9	P <0.05	S	PASS
P0044632	AMPLIFIER SPEAKER ALTO	16/08/22	P	S	P 0.14	P >99.9	P <0.05	S	PASS
P0044650	AMPLIFIER ELECTRO VOICE	16/08/22	P	S	P 0.11	P >99.9	P <0.05	S	PASS
P0044631	AMPLIFIER SPEAKER ALTO	16/08/22	P	S	P 0.13	P 27.88	P <0.05	S	PASS
C0016067	POWER LEAD	16/08/22	P	P	P 0.10	P >99.9	S	S	PASS

 Total Appliances > **84**
Total Appliances For Report: 84

Portable Appliance Testing Documentation

Client Details

Jonah`s Lift
22 Croft Parc
The Lizard
Helston
Cornwall
TR12 7PN

Test Period Commencing

16-Aug-2022

Order Number

Certificate Number PCL-002017

Company Contact Mr Bruce Jordan

Testing Carried out by

PAT Cornwall Limited
4 Roseline Estate
Carnkie
Helston
Cornwall
TR13 0XA
Phone: 01209 860665
Mobile: 07791 717358
Email: paul@patcornwall.co.uk
Web: www.patcornwall.co.uk

PATCornwall
Portable Appliance Testing throughout Cornwall